


SAFE DRINKING WATERNO. 255Date: 9/7/25

It is certified that an Inspection team headed by UDAY CHAND RAM, (Name of Officers with designation) from ASSITANT ENGINEER,PH SUB DIVISION ,GAYA JI (Name of department/Office) inspected the PRINCESS VALLEY SCHOOL,VILL- KAMALPUR, GAYA JI, BIHAR-823003 (Name & Address of the School) on 01.07.2025and on the basis of Water Test Report (attached) bearing no. 19/2025 .dated 03.07.2025 of (PHED Lab) certified that facilities for the students and members of staff of the institution. The campus as per the norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till ONE YEAR.

Signature

:



09/7/25
Assistant Engineer
P.H. Sub Division, Gaya West
Gaya

Name

: ..

Designation

: ASSISTANT ENGINEER

Name & Add. Of Department/ Office: P.H
SUB DIVISION, GAYA JI WEST,GAYA JI

To

PRINCESS VALLEY SCHOOL,
VILL- KAMALPUR, GAYA JI,
BIHAR-823003

(Name & Address of the Institution)

Public Health Engineering Department

P.H. DIVISION, GAYA

Physico-Chemical Examination Report of Drinking Water Samples of Gaya												Remarks					
Sample Collected By	MUKESH KUMAR	Sample Received on : 01.07.2025															
SL NO	Location of source			2. Desirable Limit	1.00 NTU	500 (mg/l)	200 (mg/l)	75 (mg/l)	30 (mg/l)	250 (mg/l)	200 (mg/l)	1.00 (mg/l)	6.5-8.5	45 (mg/l)	1.00 (mg/l)	200 (mg/l)	5
1	PRINCESS VALLEY SCHOOL			0.23	60	39	35	15.9	7.11	19.8	71	0.13	7.24	4.21	0.13	5	Negative
Reporting Date :	03.07.2025	Permissible Limit in absence of alternate source IS:10500:2012			5.00 NTU	-	2000 (mg/l)	600 (mg/l)	200 (mg/l)	100 (mg/l)	1000 (mg/l)	600 (mg/l)	1.50 (mg/l)	NR	NR	NR	400 (mg/l)

*NR-No Relaxation., BDL-Below Detection Limit

Shakeel
63/07/25
Chemist

P.H. Division, Gaya
Chemist
P.H. Division, Gaya